



Licensing Legend

—	Extent of Premises
—	Sale and Consumption of Alcohol Regulated Entertainment Late Night Refreshment
	Maintained Exit Sign
FD30s	Fire Door, 30mins resistance with cold smoke seals and door closer
FD60s	Fire Door, 60mins resistance with cold smoke seals and door closer
	6 ltr AFFF foam extinguisher fixed to wall with handle 1.1m above FFL
	2kg CO2 extinguisher fixed to wall with handle 1.1m above FFL
	Dry Powder Extinguisher
	Fire Blanket in Container
	Water Fire Extinguisher - 9L
	Water Fire Extinguisher - 6L with Additive
	Fat Fighter
FE	'Fire Exit' notice to BS 5499 Part 1 (Arrows indicating point to nearest exit). Letter size shown in mm. Running man symbol included.
FEI	'Fire Exit' sign illuminated by escape lighting system. Letter size shown in mm.
N1	Fire Notice Sign
N2	'Fire Exit - Keep Clear' notice
N3	'Fire Door - Keep Shut' notice
N4	'Fire Door - Keep Locked Shut' notice
N5	'Push Bar To Open' notice
AWD	Audible warning device
E	230v maintained emergency light
S	Smoke Detector
H	Heat Detector
FAP	Fire Alarm Panel
BGC	Break Glass Call Point
AS	Alarm Sounder
CP	Call Point

This drawing is protected under Copyright .
 Copyright remains the property of PLAY DESIGN CONSULTANTS unless otherwise assigned.
 Figured dimensions only to be taken from this drawing.
 DO NOT SCALE. All dimensions to be verified on site prior to the commencement of work .
 Any structural information on this drawing is indicative only .
 No structural details to be taken from this drawing ,all structural details to be referred to a structural engineer.
 All contractors must visit the site and be responsible for checking all setting out dimensions .Notify PLAY DESIGN CONSULTANTS of any discrepancies prior to any manufacture or construction works.

REV	DATE	DESCRIPTION	BY	APPROVED

PLAY DESIGN CONSULTANTS LTD
 24 Market Street
 Bromsgrove
 Worcestershire
 B61 8DA

CLIENT		THE ORIGINAL BOWLING CO	
PROJECT		PUTTSTARS HARROW	
DRAWING		LICENSING PLAN	
DRAWING NUMBER	REVISION	SHEET	
06			
JOB NO	SCALE	CAD REF	
340	1:100 (A1)	XXXX-00	
DRAWN BY	APPROVED BY	DATE	
NJT	GT	03/2023	