



- FIRE PRECAUTIONS KEY**
- ▲ Fire extinguisher (water)
  - ▲ Fire extinguisher (carbon dioxide)
  - ▲ Fire extinguisher (foam)
  - FB Fire blanket
  - FDSC30 30 minute fire resistant self closing door with smoke seals
  - FDSC60 60 minute fire resistant self closing door with smoke seals
  - KLS fire resistant doors to cupboards etc with sign "Fire door keep locked shut"
  - FE/KC doors provided only as a means of escape with sign: "Fire Escape Keep Clear"
  - SC/A doors normally held open with automatic releases connected to fire alarm system
  - FFF doors kept free of all fastenings except ball/roller catches
  - fire alarm (break glass) call point
  - 🔔 fire alarm bell or sounder
  - Ⓢ smoke detector
  - Ⓜ heat detector
  - Ⓜ visual warning device (Zenon beacon or similar) linked to fire alarm
  - Ⓜ escape sign to Health and Safety Regulations 1996 with appropriate graphic and directional arrow
  - Ⓜ internally illuminated escape sign box or luminaire, with mains and battery supply
  - Ⓜ emergency lighting to BS 5266 to this area (not showing positions of individual luminaires)
  - Ⓜ non maintained emergency light fitting
  - Ⓜ emergency light fitting with central battery pack
  - ♿ refuge area

- Supply of Alcohol
- Supply of Refreshment
- Opening Hours

REV No.	DATE	REMARKS
Client		
Job Title		
Drawing Title		
Scale	Sheet size	A2
Date	Dwn. by	
Drg. No.	Rev.	